

# IN10005

## INSTALLATION INSTRUCTIONS

1500 Cherokee Parkway, Suite 100, Acworth, GA 30102  
P: 866-845-5451 • F: 866-816-6165  
E: service@acclaim-lighting.com • www.acclaim-lighting.com

**ACCLAIM**  
LIGHTING  
INTERIOR • OUTDOOR

Please read carefully and save these instructions, as you may need them at a later date.

### CAUTION

**WARNING:** Risk of Fire. Consult a qualified electrician to ensure correct branch circuit conductor. Min 90°C supply conductors.

Turn off the main power at the circuit breaker before installing the fixture, in order to prevent possible shock.

### GENERAL

All electrical connections must be in accordance with local and National Electrical Code (N.E.C.) standards. If you are unfamiliar with proper electrical wiring connections obtain the services of a qualified electrician.

Remove the fixture and the mounting package from the box and make sure that no parts are missing by referencing the illustrations on the installation instructions.

### ASSEMBLY AND INSTALLATION

1. Thread the socket assembly (20) through glass shade (19) to the cap assembly (18), then thread the loop (17) to the cap assembly (18).
2. Connect one end of the chain (16) to the screw collar loop (14) using a chain lock (15). Connect another end of the chain (16) to the loop (17) using another chain lock (15).
3. Run fixture wire through chain (16), canopy (12), and nipple (11).
4. Pull out the outlet wire and ground wire from the outlet box (1). Make wire connections.
  - Ribbed wire (w/o marking) from light to White wire (2) from power source.
  - Smooth wire (w/o marking) from light to Black wire (3) from power source.
  - Loop the ground wire (4) to cross bar (6) with a ground screw (7).
5. Secure the cross bar (6) to the outlet box (1) with mounting screw (8). Thread hex nut (10) onto nipple (11). Insert lock washer (9) and thread the nipple (11) into the mounting strap, then secure with the hex nut (10).
6. Thread screw collar loop (14) into threaded ring (13). Attach onto nipple (11) through canopy (12) and Secure with threaded ring (13).
7. Install bulbs: (bulbs not included)  
(Do not exceed the maximum capacity recommended on the sockets).

INSTALLATION IS NOW COMPLETED

